



# *City of Rialto*

## *California*

February 14, 2019

Mark Bachli  
CDRE Holdings 11, LLC  
523 Main Street  
El Segundo, CA 90245

**RE: PRECISE PLAN OF DESIGN NO. 2018-0021 (MASTER CASE NO. 2018-0024):**  
Development of a 99,999 square foot industrial warehouse building and associated paving, drainage, lighting, fencing, and landscaping on 4.63 gross acres of land (APNs: 0240-181-32 & -33) located on the north side of Base Line Road approximately 315 feet east of Palmetto Avenue within the Employment (EMP) zone of the Renaissance Specific Plan.

Dear Mr. Bachli:

Thank you for the opportunity to review your proposed development. The City of Rialto appreciates and recognizes your commitment to our community. This letter includes conditions of approval, compiled by various divisions and departments in order to make your review process more expedient and convenient.

The City of Rialto is here to make the development of your project a priority and to assure that it is processed in a timely manner. If you need any additional assistance, please do not hesitate to contact me at (909) 820-2535.

On Wednesday, January 23, 2019, the City's Development Review Committee (DRC) approved **Precise Plan of Design No. 2018-0021**, subject to the attached requirements.

Approval of Precise Plan of Design No. 2018-0021 shall not be final until the Applicant has signed the enclosed Statement of Acceptance of Conditions of Approval. The Building and Public Works Department will not begin plan checking for building or grading permits until the signed Statement of Acceptance has been filed with the Planning Division.


DRC approval, as outlined above, does not necessarily imply immediate issuance of building or grading permits. Where applicable, the Applicant is required to submit final engineering and building plans and specifications to the Public Works and the Building Division for plan checking. Time frames for this processing will vary depending on City workload, the complexity of the project and timely submittals.

If you are aggrieved by any of the Conditions set forth in this approval letter, please contact the appropriate staff member as identified in the Conditions of Approval. If you still wish to discuss the justification for a particular condition and prefer to discuss this with the Development Review Committee (DRC), please contact the Planning Division at (909) 820-2535, in order to schedule a meeting with the DRC. Pursuant to City Council Resolution No. 2507, if you still do not concur with the Conditions of Approval by the (DRC), you may appeal the DRC conditions to the Planning Commission. The written appeal shall be filed to the Development Services Department and shall specifically state why you disagree with the Conditions of Approval set forth by the DRC.

Additionally, please take the time to complete the enclosed *Development Review Process Survey*. Your input will greatly assist us in providing the best possible service to residents, developers, and organizations doing business within the City of Rialto.

Should you have any questions or if we may be of any assistance, please do not hesitate to contact this office.

Sincerely,



Gina M. Gibson-Williams  
Planning Manager

Enclosures

PPD No. 2018-0021 Conditions

cc: Development Review Committee (via email)  
CDRE Holdings 11, LLC (via email)



# City of Rialto

## California

### DEVELOPMENT REVIEW COMMITTEE

#### STATEMENT OF ACCEPTANCE

I, MARK BACHLI, dba CDRE Holdings II LLC,  
do hereby state that I am aware of all Conditions of Approval for **Precise Plan of Design**  
**No. 2018-0021 (Master Case No. 2018-0078)** and do hereby agree to accept and abide by  
all conditions set forth in the approval letter dated February 14, 2019.

MARK BACHLI / AUTHORIZED SIGNER  
(Print Name/Title)

MB  
(Signature)

3/7/2019  
(Date)





# Project Conditions

## City of Rialto

**Project Number: PPD2018-0021**

**Description: New 99,999sf warehouse development on 4.63 gross acres**

**Applied: 3/8/2018**

**Approved: 1/23/2019**

**Site Address: BASELINE AVE**

**Closed:**

**Expired:**

**City, State Zip Code: RIALTO, CA 92376**

**Status: APPROVED**

**Applicant: CDRE HOLDINGS 11, LLC**

**Parent Project: MC2018-0024**

**Owner: CDRE HOLDINGS 11, LLC**

**Contractor: <NONE>**

**Details:**

LIST OF CONDITIONS					
SEQ NO	ADDED DATE	REQUIRED DATE	SATISFY DATE	TYPE	STATUS
DEPARTMENT		CONTACT		REMARKS	
1	3/20/2018			B1	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes:					
Provide three to five (3-5) full sets of construction plans and documentation for plan review of the proposed project. Below you will find a list of the plans and documents Building and Safety will need for plan review. The initial plan review will take approximately two weeks on most projects. Provide the following sets of plans and documents. Building and Safety submittal required at first plan review					
2	3/20/2018			B2	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes:					
(3-5) Full Architectural and Structural Plans with all MEP plans(2) Structural Calculations (2) Sets of Truss Calculations and Layout (2) Rough Grading Plans approved by Engineering (2) Water Quality Management Plan, (WQMP) and Erosion Control Plan (2) Storm water Pollution Prevention Plan (2) Title 24 Energy Calculations					
3	3/20/2018			B3	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes:					
All structures shall be designed in accordance with the 2016 California Building Code, 2016 California Mechanical Code, 2016 California Plumbing Code, and the 2016 California Electrical Code, 2016 Residential Code and the 2016 California Green Buildings Standards adopted by the State of California.					
4	3/20/2018			B4	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes:					
Scope of work on Title page with all proposed work called out that you want permitted (ex. Main structure, perimeter walls, trash enclosure, light standards)					
5	3/20/2018			B5	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes:					
Any and all deferred submittals must be approved prior to first submittal					





## Project Conditions City of Rialto

6	3/20/2018			B6	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: The Developer/Owner is responsible for the coordination of the final occupancy. The Developer/Owner shall obtain clearances from each department and division prior to requesting a final building inspection from Building and Safety. Each department shall sign the bottom of the Building and Safety Job Card					
7	3/20/2018			B7	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Building and Safety inspection requests can be made twenty four (24) hours in advance for next day inspection. Please contact (909) 820-2505 to schedule an inspection. You may also request inspections at the Building and Safety public counter					
8	3/20/2018			B8	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: All construction sites must be protected by a security fence and screening. The fencing and screening shall be maintained at all times to protect pedestrians					
9	3/20/2018			B9	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Temporary toilet facilities shall be provided for construction workers. The toilet facilities shall be maintained in a sanitary condition. Construction toilet facilities of the non-sewer type shall conform to ANSI ZA.3					
10	3/20/2018			B10	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Design criteria for the City of Rialto are: Ultimate wind speed of 130, exposure C seismic zone D					
11	3/20/2018			B11	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Construction projects which require temporary electrical power shall obtain an Electrical Permit from Building and Safety. No temporary electrical power will be granted to a project unless one of the following items is in place and approved by Building and Safety and the Planning Department. (A) Installation of a construction trailer, or, (B) Security fenced area where the electrical power will be located					
12	3/20/2018			B12	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Installation of construction/sales trailers must be located on private property. No trailers can be located in the public street right of way					





## Project Conditions City of Rialto

13	3/20/2018			B13	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Site development and grading shall be designed to provide access to all entrances and exterior ground floors exits and access to normal paths of travel, and where necessary to provide access. Paths of travel shall incorporate (but not limited to) exterior stairs, landings, walks and sidewalks, pedestrian ramps, curb ramps, warning curbs, detectable warning, signage, gates, lifts and walking surface materials. The accessible route(s) of travel shall be the most practical direct route between accessible building entrances, site facilities, accessible parking, public sidewalks, and the accessible entrance(s) to the site, California Building Code, (CBC) Chapter 11, Sec, 11A and 11B					
14	3/20/2018			B14	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: The City enforces the State of California provisions of the California Building Code disabled access requirements. The Federal Americans with Disabilities Act (ADA) standards may differ in some cases from the California State requirements, therefore it is the building owners responsibility to be aware of those differences and comply accordingly					
15	3/20/2018			B15	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Site facilities such as parking open or covered, recreation facilities, and trash dumpster areas, and common use areas shall be accessible per the CBC, Chapter 11					
16	3/20/2018			B16	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Separate permits are required for all accessory structures; example would be detached trash enclosures, patios, block walls, and storage buildings					
17	3/20/2018			B17	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Provide location on plans for "Illuminated address/es"					
18	3/20/2018			B18	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Pursuant to the California Business and Professions Code Section 6737, most projects are required to be designed by a California Licensed Architect or Engineer. The project owner or developer should review the section of the California Codes and comply with the regulation					
19	3/20/2018			B19	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Fire sprinklers, fire alarm systems and fire hydrant plans shall be submitted for plan review concurrently with building plans and shall be approved prior to permit issuance					





## Project Conditions City of Rialto

20	3/20/2018			B20	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> When required, three (3) copies of the building plans shall be submitted to the County Department of Environmental Health for approval, prior to submittal of the plans to the Building Division for plan review. Permits will not be issued or plans approved until two copies of the approved health plans have been received and reviewed by the Building Division					
21	3/20/2018			B21	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> Normal Building Division business hours are Monday through Thursday between 7:00 a.m. and 6:00 p.m. Normal Inspection hours are 8:00 a.m. to 5:00 p.m. Inspection requests shall be made at least one business day prior to the inspection date. No overtime inspections are available and deputy inspectors shall not perform required inspection under any circumstance					
22	3/20/2018			B22	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> Permitted hours for construction work from October 1st through April 30th are Monday Friday, 7:00 a.m. to 5:30 p.m. and Saturday 8:00 a.m. to 5:00 p.m. From May 1st through September 30th permitted hours for construction is Monday- Friday, 6:00 a.m. to 7:00 p.m. and Saturday 8:00 a.m. to 5:00 p.m. Construction is prohibited on Sundays and State holidays					
23	3/20/2018			B23	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> Place PPD conditions of approval on the plans and include the PPD number on right bottom corner cover page in 20 point bold					
24	3/20/2018			B24	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> 65% of all construction and demo debris shall be recycled using an approved City of Rialto recycling facility. Copies of receipts for recycling shall be provided to the City Inspector and a copy shall be placed in the office of the construction site					
25	3/20/2018			B25	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> Due to the proximity to the San Andreas Fault and the constant ground movement, the following are required: 1. All underground piping/conduits will have 6 of sand shading under and 12 of sand shading over. 2. All electrical runs with a hot and common wire will have a ground wire					
26	3/20/2018			B26	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
<b>Notes:</b> Prior to the issuance of a Building Permit, the applicant shall pay all Development Improvement Fees to the City. Copies of receipts shall be provided to Building and Safety prior to permit issuance					





## Project Conditions City of Rialto

27	3/20/2018			B27	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Prior to issuance of a Building Permit all of the following must be in place: portable toilet with hand wash station, all BMP's, fencing and signage on each adjacent street saying "If there is any dust or debris coming from this site please contact (superintendent number here) or the AQMD if the problem is not being resolved" or something similar to this.					
28	3/20/2018			B28	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: All on site utilities shall be underground to the new proposed structure unless prior approval has been obtained by the utility company or the City					
29	3/20/2018			B29	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Prior to issuance of Building Permits, on site water service shall be installed and approved by the responsible agency. On site fire hydrants shall be approved by the Fire Department. No flammable materials will be allowed on the site until the fire hydrants are established and approved					
30	3/20/2018			B30	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Prior to issuance of Building Permits, site grading final and pad certifications shall be submitted to Building and Safety to include elevation, orientation, and compaction. The certifications are required to be signed by the engineer of record					
31	3/20/2018			B31	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Prior to issuance of Building Permits, school fees need to be paid to school district where project is located					
32	3/20/2018			B32	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Prior to issuance of Building Permits, Precise Grading Plans approved by Engineering.					
33	3/20/2018			B33	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: All construction projects shall comply with the National Pollutant Discharge Elimination Systems (NPDES) and the current County of San Bernardino Storm Water Permit, MS-4					
34	3/20/2018			B34	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: Per Rialto Fire, provide permanent or temporary fire protection before construction					





## Project Conditions City of Rialto

35	3/20/2018			B35	PPD CONDITION
BUILDING DIVISION		JAMES CARO			
Notes: No "Future" or "Proposed" items on plans					
36	3/30/2018			ED1	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
Notes: The proposed project is subject to the payment of Development Impact Fees pursuant to Rialto Municipal Code, Section 3.33.					
37	3/30/2018			ED3	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
Notes: Applicant/Developer shall be assessed and shall pay the following development impact fees estimated below prior to the issuance of building permits or prior to issuance of Certificate of Occupancy (Residential Only). Fees noted below are subject to annual adjustments as established by the current fee ordinance. Fees shall be assessed and paid at the current amount as of the date payment is made in full.					
38	3/30/2018			ED4	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
Notes: Applicant/Developer has the right to protest the imposition of any development impact fee or exaction for the project. Developer shall have ninety (90) days from the date these conditions are established in which to challenge or protest the amount of the fees or exactions assessed upon the project.					
39	3/30/2018			ED5	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
Notes: Applicant/Developer shall use best faith efforts provide employment opportunities for Rialto residents. The Developer/Applicant shall use best faith efforts to recruit and hire local residents for all full and part time employment opportunities during construction and as part of daily business operations. Developer/Applicant efforts shall include on-site job recruitment. The Developer/Applicant/Employer shall furnish the Development Services Department with the dates and times for on-site job recruitment, which will be posted on the City website and advertised on the Rialto Network					
40	3/30/2018			ED6	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
Notes: Applicant/Developer shall use best faith efforts to recruit and hire local contractors, laborers, and resident for any full and part time construction related employment opportunities.					
41	3/30/2018			ED7	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
Notes: Applicant/Developer shall use best faith efforts to require all contractors to purchase all construction related materials from local vendors and suppliers. Developer/Applicant shall designate and/or require their contractors and suppliers to designate the City of Rialto as the point of sale for all taxable materials and equipment purchased for the project.					





## Project Conditions City of Rialto

42	3/30/2018			ED8	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
<b>Notes:</b> Applicant/Developer shall establish and register the premises as a point of sale through the State Board of Equalization. Applicant/Developer shall report all taxable transactions conducted at, on or through the business operations located on the premises.					
43	3/30/2018			ED9	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
<b>Notes:</b> Project is located within the Renaissance Specific Plan Area and is subject to the Renaissance Specific Plan /EIR Fee and the Renaissance Specific Plan Fair Share Traffic Fee.					
44	3/30/2018			ED10	PPD CONDITION
ECONOMIC DEV DIV		JOHN DUTREY			
<b>Notes:</b> The City of Rialto is currently developing a smarter advanced logistics and transportation system that will report, monitor and coordinate truck trips coming into and leaving the local and regional transportation and roadway network. If implemented by the City of Rialto and/or another regional transportation agency(ies), all distribution warehouses, logistics companies or other businesses dependent upon the shipment of goods that maintain and operate a facility in the City of Rialto will be asked to participate in and subscribe to this advanced logistics transportation system, which will monitor, track and coordinate all truck trips and shipments of goods into and out of the City of Rialto and the regional transportation system. As may be approved, enacted or implemented by the City or other local, regional or State government agency, all PCE trips generated may be subject to a time of use, congestion, roadway impact pricing, and/or be eligible for carbon credits or reductions or off-sets to such time of use mitigation fees that may be imposed for coordinating shipments of goods during off peak hours.					
51	4/4/2018			BL1	PPD CONDITION
BUSINESS LICENSE DIV		GINA GIBSON WILLIAMS			
<b>Notes:</b> The Developer or General Contractor shall identify each contractor and subcontractor hired to work at the job site on the Contractor Sublist form and return it to the Business License Division with a Business License application and the Business License tax fee based on the Contractors tax rate for each contractor listed on the form (see attached)					
52	4/4/2018			BL4	PPD CONDITION
BUSINESS LICENSE DIV		GINA GIBSON WILLIAMS			
<b>Notes:</b> Prior to issuance of a Certificate of Occupancy, a Business License tax shall be paid based on the following tax: Distribution Centers					
53	1/10/2019			P1	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> Precise Plan of Design No. 2018-0021 is approved allowing the development of a 99,999 square foot industrial warehouse building and associated paving, drainage, lighting, fencing, and landscaping on 4.63 gross acres (4.61 net acres) of land (APNs: 0240-181-32 & -33) located on the north side of Base Line Road approximately 315 feet east of Palmetto Avenue, subject to the conditions of approval contained herein.					





## Project Conditions

### City of Rialto

54	1/10/2019			P2	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: The approval of Precise Plan of Design No. 2018-0021 is granted for a one (1) year period from the date of approval. Any request for an extension shall be reviewed by the Development Review Committee and shall be based on the progress that has taken place toward the development of the project.					
55	1/10/2019			P3	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: The development associated with Precise Plan of Design No. 2018-0021 shall conform to the site plan, floor plan, roof plan, elevations, conceptual landscape plan, and conceptual grading plan received by the Planning Division on June 21, 2018, except as may be required to be modified based on the conditions of approval contained herein.					
56	1/10/2019			P4	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: The development associated with Precise Plan of Design No. 2018-0021 shall comply with all applicable sections of the Renaissance Specific Plan, the Rialto Municipal Code, and all other applicable State and local laws and ordinances.					
57	1/10/2019			P5	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: The applicant shall comply and abide by all conditions of approval contained within Planning Commission Resolution No. 19-02 prior to the issuance of a Certificate of Occupancy.					
58	1/10/2019			P6	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: The applicant shall complete and abide by all mitigation measures contained within the Mitigation Monitoring and Reporting Program associated with the Mitigated Negative Declaration (Environmental Assessment Review No. 2018-0024) adopted for the project, prior to the issuance of a Certificate of Occupancy.					
59	1/10/2019			P7	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: City inspectors shall have access to the site to reasonably inspect the site during normal working hours to assure compliance with these conditions and other codes.					
60	1/10/2019			P8	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes: The applicant shall defend, indemnify and hold harmless the City of Rialto, its agents, officers, or employees from any claims, damages, action, or proceeding against the City or its agents, officers, or employees to attack, set aside, void or annul, and approval of the City, its advisory agencies, appeal boards, or legislative body concerning Precise Plan of Design No. 2018-0021. The City will promptly notify the applicant of any such claim, action, or proceeding against the City and will cooperate fully in the defense.					





## Project Conditions City of Rialto

61	1/10/2019			P9	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall secure the services of a tribal cultural monitor to be present during all ground disturbance activities associated with the construction of this project. The tribal cultural monitor shall be approved by the Gabrieleño Band of Mission Indians-Kizh Nation, and documentation of coordination between the applicant and the Gabrieleño Band of Mission Indians-Kizh Nation on this matter shall be provided to the Planning Division prior to the issuance of a grading permit.					
62	1/10/2019			P10	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall record a reciprocal driveway easement with the owner of the property adjacent to the west of the project site (APN: 0240-181-13), prior to the issuance of a grading permit. The easement shall grant the adjacent property owner access to the proposed driveway on Base Line Road, in accordance with the approved site plan.					
63	1/10/2019			P11	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The proposed public art shall be setback a minimum of five (5) feet behind the landscape easement along Base Line Road. The exact location of the public art shall be identified on the precise grading plan prior to the issuance of a grading permit. An elevation detail for the public art shall be included in the formal building plan check submittal prior to the issuance of buildings permits. The applicant shall obtain a building permit from the Building Division for the public art, and construction of the public art shall be complete prior to the issuance of the Certificate of Occupancy.					
64	1/10/2019			P12	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall install decorative pavement within each driveway connected to Base Line Road. The decorative pavement shall extend across the entire width of each driveway and shall have a minimum depth of twenty-eight (28) feet as measured from the property line along Base Line Road. Decorative pavement means decorative pavers and/or color concrete with patterns and color variety. The location of the decorative pavement shall be identified on the Precise Grading Plan prior to the issuance of a grading permit, and it shall also be identified on the site plan within the formal building plan check submittal prior to the issuance of building permits. The type of decorative pavement shall be identified on the formal Landscape Plan submittal prior to the issuance of building permits.					
65	1/10/2019			P13	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> In order to provide enhanced building design in accordance with Section 4 of the Renaissance Specific Plan (Design Guidelines), the applicant shall route all downspouts through the interior of the building. The internal downspouts shall be identified within the formal building plan check submittal prior to the issuance of building permits.					
66	1/10/2019			P14	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> In order to provide enhanced building modulation in accordance with Section 4 of the Renaissance Specific Plan (Design Guidelines), façade returns, at least three (3) feet in depth from the main wall plane, shall be provided at all height variations on all four (4) sides of the building. The façade returns shall be demonstrated on the roof plans within the formal building plan check submittal prior to the issuance of building permits.					





## Project Conditions City of Rialto

67	1/10/2019			P15	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes:					
All new walls installed on site, including retaining walls, shall be comprised of decorative masonry block or decorative concrete. Decorative masonry block means tan slumpstone block, tan split-face block, or precision block with a stucco, plaster, or cultured stone finish. Decorative concrete means painted concrete with patterns, reveals, and/or trim lines. Pilasters shall be incorporated within all new walls visible from the public right-of-way. The pilasters shall be spaced a maximum of seventy (70) feet on-center and shall be placed at all corners and ends of the wall. All pilasters shall protrude a minimum six (6) inches above and to the side of the wall. All decorative masonry walls and pilasters shall include a decorative masonry cap. All walls and pilasters shall be identified on the site plan, and an elevation detail for the walls shall be included in the formal building plan check submittal prior to the issuance of building permits.					
68	1/10/2019			P16	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes:					
All entryways into the truck court shall be secured with solid metal gates up to the height of the adjoining wall for the purpose of screening trucks and trailers parked within the truck court. All new gates shall be identified on the site plan, and an elevation detail for the gates shall be included in the formal building plan check submittal prior to the issuance of building permits.					
69	1/10/2019			P17	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes:					
All new fencing installed on site shall be comprised of tubular steel. Decorative masonry or decorative concrete pilasters, with a minimum dimension of sixteen (16) inch square, shall be incorporated within all new fencing visible from any public right-of-way. Decorative masonry block means tan slumpstone block, tan split-face block, or precision block with a stucco, plaster, or cultured stone finish. Decorative concrete means painted concrete with patterns, reveals, and/or trim lines. The pilasters shall be spaced a maximum of seventy (70) feet on-center and shall be placed at all corners and ends of the fencing. All decorative masonry pilasters shall include a decorative masonry cap. All fencing and pilasters shall be identified on the site plan, and an elevation detail for the fencing and pilasters shall be included in the formal building plan check submittal prior to the issuance of building permits.					
70	1/10/2019			P18	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes:					
The applicant shall construct an ADA accessible trash enclosure on the project site. The trash enclosure shall provide room for one (1) commercial waste container and one (1) commercial recycling container. The exterior of the trash enclosure shall match the material and base color of the building. Additionally, the trash enclosure shall contain solid steel doors and a flat solid cover. Corrugated metal and chain-link are not acceptable materials to use as a part of the trash enclosure. The location of the trash enclosure shall be identified on the site plan within the formal building plan check prior to the issuance of building permits. An elevation detail for the trash enclosures shall be provided within formal building plan check submittal prior to the issuance of building permits.					
71	1/10/2019			P19	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
Notes:					
All light standards installed on site, shall have a maximum height of twenty-five (25) feet, including the base, as measured from the finished surface. Lighting shall be shielded and/or directed toward the site so as not to produce direct glare or "stray light" onto adjacent properties. All light standards shall be identified on the site plan and a note indicating the height restriction shall be included within the formal building plan check submittal prior to the issuance of building permits.					





## Project Conditions City of Rialto

72	1/10/2019			P20	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall submit a formal Landscape Plan to the Planning Division prior to the issuance of building permits. The submittal shall include three (3) sets of planting and irrigation plans, a completed Landscape Plan Review application, and the applicable review fee.					
73	1/10/2019			P21	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> All landscape plant species installed on site shall comply with the approved Plant Palette of the Renaissance Specific Plan.					
74	1/10/2019			P22	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall plant one (1) tree every three (3) parking spaces. All parking lot trees shall be a minimum of fifteen (15) gallons in size, upon initial planting. Thereafter, the parking lot trees shall be permanently irrigated and maintained. All parking lot tree species shall consist of evergreen broadleaf trees. The trees shall be identified on the formal Landscape Plan submittal prior to the issuance of a landscape permit.					
75	1/10/2019			P23	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall plant one (1) tree every thirty (30) feet on-center within the on-site landscape setback along Base Line Road. All trees within the landscape setbacks shall be a minimum of twenty-four (24) inch box in size, upon initial planting. Thereafter, the trees within the landscape setback shall be permanently irrigated and maintained. At least fifty (50) percent of the trees within the setbacks shall consist of evergreen broadleaf trees, while the remaining percentage may consist of broadleaf deciduous trees and/or palm trees. The trees shall be identified on the formal Landscape Plan submittal prior to the issuance of a landscape permit.					
76	1/10/2019			P24	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall plant one (1) tree every thirty (30) feet on-center within the public right-of-way parkway along Base Line Road. All trees within the public right-of-way parkway shall be a minimum of twenty-four (24) inch box in size, upon initial planting. Thereafter, the trees within the public right-of-way parkway shall be permanently irrigated and maintained, as required by the Public Works Department. The street tree species along Base Line Road shall be the Pyrus Calleryana "Bradford Flowering Pear" and/or the Quercus Virginiana "Southern Live Oak". The trees shall be identified on the formal Landscape Plan submittal prior to the issuance of building permits.					
77	1/10/2019			P25	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall plant shrubs that surround all ground mounted equipment and utility boxes, including transformers, fire-department connections, backflow devices, etc. for the purpose of providing screening of said equipment and utility boxes. All equipment and utility box screen shrubs shall be a minimum of five (5) gallons in size upon initial planting, and the shrubs shall be spaced no more than three (3) feet on-center. Thereafter, the equipment and utility box screen shrubs shall be permanently irrigated and maintained into a continuous box-shape with a height of no less than three and one-half (3.5) feet above the finished grade. The shrubs shall be identified on the formal Landscape Plan submittal prior to the issuance of a landscape permit.					





## Project Conditions City of Rialto

78	1/10/2019			P26	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall plant a substantial amount of trees, shrubs, and groundcover vegetation throughout all land on-site and off-site that is not covered by structures, walkways, parking areas, and driveways. Trees shall be planted a minimum of thirty (30) feet on-center, and all shrubs and groundcover shall be planted an average of three (3) feet on-center or less. All trees shall be minimum of fifteen (15) gallons in size upon initial planting, unless otherwise specified herein. All shrubs shall be a minimum of one (1) gallon in size, unless otherwise specified herein. All planter areas shall receive a minimum two (2) inch thick layer of brown bark, organic mulch, and/or decorative rock upon initial planting. Pea gravel and decomposed granite are not acceptable materials to use within on-site and off-site planter areas. All planter areas on-site shall be permanently irrigated and maintained. The planting and irrigation shall be identified on the formal Landscape Plan submittal prior to the issuance of a landscape permit.					
79	1/10/2019			P27	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> All planting and irrigation shall be installed on-site in accordance with the approved landscape plans and permit prior to the issuance of a Certificate of Occupancy. The installation of the planting and irrigation shall be certified in writing by the landscape architect responsible for preparing the landscape plans prior to the issuance of a Certificate of Occupancy.					
80	1/10/2019			P28	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall install a bicycle rack within the pathway area near the entrance of the building prior to the issuance of a Certificate of Occupancy.					
81	1/10/2019			P29	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> Any tubular steel fencing and/or sliding gates shall be painted black prior to the issuance of a Certificate of Occupancy.					
82	1/10/2019			P30	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> All non-glass doors shall be painted to match the color of the adjacent wall prior to the issuance of a Certificate of Occupancy.					
83	1/10/2019			P31	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> All signage on the building shall comply with Section 5 (Signs) of the Renaissance Specific Plan.					
84	1/10/2019			P32	PPD CONDITION
PLANNING DIVISION		DANIEL CASEY			
<b>Notes:</b> The applicant shall obtain any necessary approvals and permits that may be required by any State and local agencies prior to the issuance of a Certificate of Occupancy.					





## Project Conditions City of Rialto

85	1/23/2019			PD1	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: ALL: Lighting of pedestrian access areas. All walkways, passageways, and locations where pedestrians are likely to travel, shall be illuminated with a minimum of 1.5-foot candles (at surface level) of light during the hours of darkness. Lighting shall be designed/constructed in such a manner as to automatically turn on at dusk and turn off at dawn.					
86	1/23/2019			PD2	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: All: Lighting of vehicle access areas. All alleyways, driveways, and uncovered parking areas shall be illuminated with a minimum of 1.5-foot candles (at surface level) of light during the hours of darkness. Lighting shall be designed/constructed in such a manner as to automatically turn on at dusk and turn off at dawn.					
87	1/23/2019			PD3	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: ALL: Light fixtures and lighting hardware. All lighting fixtures and luminaries, including supports, poles and brackets, shall be designed/constructed in such a manner as to resist vandalism and/or destruction by hand.					
88	1/23/2019			PD4	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: ALL: Address shall be illuminated during hours of darkness and prominently placed to be both visible to the front of the location and if applicable, visible to the main street to which they are located (e.g. commercial building facing the interior of the property would require two address signs if located adjacent to a roadway).					
89	1/23/2019			PD5	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: ALL: Exterior security cameras shall be installed at the location and cover the entire property. The security cameras shall be accessible to the Rialto Police Department via the internet. For spec buildings it is conditioned that at time of occupancy the cameras shall be installed, functional, and approved by the Rialto Police Department.					
90	1/23/2019			PD6	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: ALL: Install MUTCD approved "No Stopping" signage along the streets adjacent to the property.					
91	1/23/2019			PD13	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
Notes: COMMERCIAL/INDUSTRIAL: Lighting of truck well/dock/delivery areas. All loading dock areas truck well areas, and delivery areas shall be provided with a minimum of two (2) foot candles power as measured at the surface level. Lighting shall be designed/constructed in such a manner as to turn on at dusk and off at dawn automatically.					





## Project Conditions City of Rialto

92	1/23/2019			PD14	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
<b>Notes:</b> COMMERCIAL/INDUSTRIAL: Knox boxes. (All that apply) The main gate, main doors to the building, and at least one rear door to each suite, shall have, immediately adjacent to them, a Knox box to facilitate the entry of safety personnel. Knox boxes shall be installed in such a manner as to resist vandalism, removal, or destruction by hand, and be fully recessed into the building. Knox Boxes shall be equipped with the appropriate keys, for each required location, prior to the first day of business.					
93	1/23/2019			PD16	PPD CONDITION
POLICE DEPARTMENT		SGT. JOSHUA LINDSAY			
<b>Notes:</b> "COMMERCIAL/INDUSTRIAL: Address prominently displayed on all building rooftops visible to aerial law enforcement or fire aircraft. Specifications to be followed for alphanumeric characters are as follows: Three (3) foot tall and six (6) inches thick alphanumeric characters. The alphanumeric characters shall be constructed in such a way that they are in stark contrast to the background to which they are attached (e.g. white numbers and letters on a black background), and resistant weathering that would cause a degradation of the contrast. Suite numbers are required on all buildings with multiple suites and shall be located directly above the respective suites following the above listed guidelines."					
94	1/23/2019			EN2	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> GENERAL: All requirements shall be completed to the satisfaction of the City Engineer prior to issuance of a certificate of occupancy unless otherwise noted					
95	1/23/2019			EN3	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> GENERAL: Prior to issuance of a building permit, the developer shall pay all applicable development impact fees in accordance with the current City of Rialto fee ordinance including Transportation Fair Share Contribution fees					
96	1/23/2019			EN4	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> GENERAL: Prior to issuance of a building permit, The Precise Grading/Paving Plan shall be approved by the City Engineer					
97	1/23/2019			EN5	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> GENERAL: Any improvements within the public right-of-way require a City of Rialto Encroachment Permit					





## Project Conditions City of Rialto

98	1/23/2019			EN6	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> Submit California registered civil engineer prepared street improvement plans to the Engineering Division of Public Works for review and approval. Unless otherwise approved, approved, the street improvement plans shall be approved concurrently with any street light, landscape and irrigation, and traffic signal plans. The plans shall be City Engineer approved prior to issuance of any building permits.					
99	1/23/2019			EN7	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> Submit California registered civil engineer or traffic engineer prepared traffic striping and signage plans for review and approval. All required traffic thermoplastic striping and signage improvements shall be completed concurrently with street improvements to the satisfaction of the City Engineer and prior to issuance of a building permit.					
100	1/23/2019			EN8	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> Submit off-site landscaping and irrigation system improvement plans for review and approval at the time of first (1st) public improvement plan submittal to the Public Works Department. The median irrigation system shall be separately metered from the on-site private irrigation to be maintained for a period of one (1) year and annexed into a Special District. The off-site landscape and irrigation plans must show separate electrical and water meters to be annexed into the Landscape and Lighting Maintenance District No. 2 via a City Council Public Hearing. The landscape and irrigation plans shall be approved concurrently with the street improvement plans, including the median portion, prior to issuance of a building permit. The landscaping architect must contact the City of Rialto Landscape Contract Specialist at (909) 772-2635 to ensure all landscape and irrigation guidelines are met prior to plan approval. Electrical and water irrigation meter pedestals must not be designed to be installed at or near street intersections or within a raised median to avoid burdensome traffic control set-up during ongoing maintenance.					
101	1/23/2019			EN9	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> All median and/or parkway landscaping shall be guaranteed for a period of one year from the date of the City Engineer acceptance. Any landscaping that fails during the one year landscape maintenance period shall be replaced with similar plant material to the satisfaction of the City Engineer, and shall be subject to a subsequent one year landscape maintenance period. The applicant must contact the City of Rialto Landscape Contract Specialist at (909) 772-2635 to confirm a full twelve (12) months' time of non-interrupted ongoing maintenance.					
102	1/23/2019			EN10	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> All proposed trees within the public right-of-way and within 10 feet of the public sidewalk and/or curb shall have City approved deep root barriers installed in accordance with the Public Works Landscape and Irrigation Guidelines.					





## Project Conditions City of Rialto

103	1/23/2019			EN11	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> The developer shall apply for annexation of the underlying property into City of Rialto Landscape and Lighting Maintenance District No. 2 ("LLMD 2"). An application fee of \$5,000 shall be paid at the time of application. Annexation into LLMD 2 is a condition of acceptance of any new median and/or parkway landscaping in the public right-of-way, or any new public street lighting improvements, to be maintained by the City of Rialto. Due to the required City Council Public Hearing action, the annexation process takes months and as such the developer is advised to apply for Special District annexation early in the process to avoid any delays at Certificate of Occupancy.					
104	1/23/2019			EN12	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> All new street lights shall be installed on an independently metered, City-owned underground electrical system. The developer shall be responsible for applying with Southern California Edison ("SCE") for all appropriate service points and electrical meters early in the process to avoid delays. The developer must pay for the electrical service of new meter pedestals installed until such time as the improvements have been accepted and the underlying property is annexed into LLMD 2. The applicant must contact the City of Rialto Landscape Contract Specialist at (909) 772-2635 to confirm a full twelve (12) months' time of non-interrupted ongoing maintenance.					
105	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> The developer is responsible for requesting from the Public Works Department any addresses needed for any building(s) and/or any electrical/water single/dual irrigation meter pedestal(s).					
106	1/23/2019			EN13	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> Construct asphalt concrete paving for streets in two separate lifts. The final lift of asphalt concrete pavement shall be postponed until such time that on-site construction activities are complete, as may be determined by the City Engineer. Paving of streets in one lift prior to completion of on-site construction will not be allowed, unless prior authorization has been obtained from the City Engineer. Completion of asphalt concrete paving for streets prior to completion of on-site construction activities, if authorized by the City Engineer, will require additional paving requirements prior to acceptance of the street improvements, including, but not limited to: removal and replacement of damaged asphalt concrete pavement, overlay, slurry seal, or other repairs, as required by the City Engineer.					
107	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b> All street cuts for utilities shall be repaired in accordance with City Standard SC-231 within 72 hours of completion of the utility work; and any interim trench repairs shall consist of compacted backfill to the bottom of the pavement structural section followed by placement of standard base course material in accordance with the Standard Specifications for Public Work Construction ("Greenbook"). The base course material shall be placed the full height of the structural section to be flush with the existing pavement surface and provide a smooth pavement surface until permanent cap paving occurs using an acceptable surface course material.					






## Project Conditions City of Rialto

108	1/23/2019			EN14	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b>  Any utility trenches or other excavations within existing asphalt concrete pavement of off-site streets required by the proposed development shall be backfilled and repaired in accordance with City of Rialto Standard Drawings. The developer shall be responsible for removing, grinding, paving and/or overlaying existing asphalt concrete pavement of off-site streets as required by and at the discretion of the City Engineer, including pavement repairs in addition to pavement repairs made by utility companies for utilities installed for the benefit of the proposed development (i.e. Fontana Water Company, Southern California Edison, Southern California Gas Company, Time Warner, Verizon, etc.). Multiple excavations, trenches, and other street cuts within existing asphalt concrete pavement of off-site streets required by the proposed development may require complete grinding and asphalt concrete overlay of the affected off-site streets, at the discretion of the City Engineer. The pavement condition of the existing off-site streets shall be returned to a condition equal to or better than what existed prior to construction of the proposed development.					
109	1/23/2019			EN15	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b>  In accordance with Chapter 15.32 of the City of Rialto Municipal Code, all existing electrical distribution lines of sixteen thousand volts or less and overhead service drop conductors, and all telephone, television cable service, and similar service wires or lines, which are on-site, abutting, and/or transecting, shall be installed underground. Utility undergrounding shall extend to the nearest off-site power pole; no new power poles shall be installed unless otherwise approved by the City Engineer. A letter from the owners of the affected utilities shall be submitted to the City Engineer prior to approval of the Grading Plan, informing the City that they have been notified of the City's utility undergrounding requirement and their intent to commence design of utility undergrounding plans. When available, the utility undergrounding plan shall be submitted to the City Engineer identifying all above ground facilities in the area of the project to be undergrounded.					
110	1/23/2019			EN16	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b>  All damaged, destroyed, or modified pavement legends, traffic control devices, signing, striping, and street lights, associated with the proposed development shall be replaced as required by the City Engineer prior to issuance of a Certificate of Occupancy.					
111	1/23/2019			EN17	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b>  Construction signing, lighting and barricading shall be provided during all phases of construction as required by City Standards or as directed by the City Engineer. As a minimum, all construction signing, lighting and barricading shall be in accordance with Part 6 Temporary Traffic Control of the 2014 California Manual on Uniform Traffic Control Devices, or subsequent editions in force at the time of construction.					





## Project Conditions City of Rialto

112	1/23/2019			EN18	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b>  Upon approval of any improvement plan by the City Engineer, the improvement plan shall be provided to the City in digital format, consisting of a DWG (AutoCAD drawing file), DXF (AutoCAD ASCII drawing exchange file), and PDF (Adobe Acrobat) formats. Variation of the type and format of the digital data to be submitted to the City may be authorized, upon prior approval by the City Engineer.					
113	1/23/2019			EN19	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GENERAL:</b>  The public street improvements outlined in these conditions of approval are intended to convey to the developer an accurate scope of required improvements, however, the City Engineer reserves the right to require reasonable additional improvements as may be determined in the course of the review and approval of street improvement plans required by these conditions					
114	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>TRANSPORTATION:</b> Prior to the issuance of a building permit, the developer is required to pay Transportation Commission recommended Traffic Impact Analysis (TIA) Project Fair Share Contribution fees in the amount of \$31,200.00 as indicated in the September 9, 2018 Transportation Commission meeting.					
115	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>TRANSPORTATION:</b>  Pay a fair share contribution fee for the future widening of Base Line Road to three (3) full westbound lanes and pay a fair share contribution fee for the future widening of Alder Avenue to three (3) full southbound lanes as approved by the Transportation Commission at the September 9, 2019 Transportation Commission meeting.					
116	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>TRANSPORTATION:</b> Construct 4-inch conduit within the parkway area long the entire project frontage for future use.					
117	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>TRANSPORTATION:</b> Install Class II thermoplastic Bicycle Facilities as referenced on the San Bernardino County Non-Motorized Transportation Plan – May 2014, Figure 5.41, Sheet 5-134 along the entire project frontage.					





## Project Conditions City of Rialto

118	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes: TRANSPORTATION: Install "No Stopping Anytime" R26A (CA) signage along the entire frontage.					
119	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes: OMNITRANS: The developer shall be responsible for coordinating with Omnitrans regarding the location of existing, proposed, and future bus stops along the property frontage of all public streets. The developer shall design street and sidewalk improvements in accordance with the latest Omnitrans bus stop guidelines and in compliance with current accessibility standards pursuant to the Americans with Disabilities Act (ADA) requirements. The developer shall design all bus stops to accommodate the Omnitrans Premium Shelters. Prior to Certificate of Occupancy, the developer shall submit to Public Works verification from Omnitrans acknowledging concurrence with the existing, proposed, and future bus stop improvements in conformance with the Premium Shelter design guidelines.					
120	1/23/2019			EN20	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes: BASE LINE ROAD (Major Arterial per RSP):  Construct a 16-foot wide raised and landscaped median island along frontage of property, as approved by the City Engineer. The median nose width shall be constructed at 4-feet wide and shall have stamped concrete. The left turn pockets shall be designed in accordance with Section 405 of the current edition of the Caltrans Highway Design Manual, and/or as approved by the City Engineer					
121	1/23/2019			EN21	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes: BASE LINE ROAD (Major Arterial per RSP):  Dedicate Renaissance Specific Plan approved additional right-of-way along the entire frontage as may be required to provide a property line at ultimate right of way of 50 feet from the street centerline. Nothing shall be constructed or planted in the corner cut-off area which does or will exceed 30 inches in height required to maintain an appropriate corner sight distance.					
122	1/23/2019			EN22	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes: BASE LINE ROAD (Major Arterial per RSP): Dedicate an 8 feet wide easement for landscape purposes along the entire frontage in accordance with the Renaissance Specific Plan in accordance with the City of Rialto Standard Drawings.					
123	1/23/2019			EN23	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes: BASE LINE ROAD (Major Arterial per RSP): Remove existing, and construct new pavement with a minimum pavement section of 5 inches asphalt concrete pavement over 6 inches crushed aggregate base with a minimum subgrade of 24 inches at 95% relative compaction, or equal, along the entire frontage in accordance with City of Rialto Standard Drawings. The pavement section shall be determined using a Traffic Index (TI) of 10. The pavement section shall be designed by a California registered Geotechnical Engineer using "R" values from the project site and submitted to the City Engineer for approval. Alternatively, depending on the existing street condition and as approved by the City Engineer, a street overlay, slurry seal, or other repair can be performed to preserve recent pavement improvements.					





## Project Conditions City of Rialto

124	1/23/2019			EN24	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes:					
BASE LINE ROAD (Major Arterial):					
Construct an 8-inch curb and gutter along the entire frontage in accordance with City of Rialto Standard Drawings.					
125	1/23/2019			EN25	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes:					
BASE LINE ROAD (Major Arterial per RS): Construct a new underground electrical system for public street lighting improvements. New marbelite street light poles with LED light fixtures shall be installed as approved by the City Engineer, in accordance with City of Rialto Standard Drawings					
126	1/23/2019			EN26	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes:					
BASE LINE ROAD (Major Arterial per RSP): Construct an Americans with Disabilities Act (ADA) compliant sidewalk behind curb along the entire frontage in accordance with the General Plan, any Specific Plan and the City of Rialto Standard Drawings.					
127	1/23/2019			EN27	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes:					
BASE LINE ROAD (Major Arterial per RSP):					
Construct a commercial driveway approach in accordance with City of Rialto Standard Drawings. The driveway approach shall be constructed so the top of X is 5 feet from the property line, or as otherwise approved by the City Engineer. Nothing shall be constructed or planted in the corner cut-off area which does or will exceed 30 inches in height required to maintain an appropriate corner sight distance					
128	1/23/2019			EN28	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes:					
BASE LINE ROAD (Major Arterial per RSP): Construct a curb ramp meeting current California State Accessibility standards along both sides of the commercial driveway approach. The developer shall ensure that an appropriate path of travel, meeting ADA guidelines, is provided across the driveway, and shall adjust the location of the access ramps, if necessary, to meet ADA guidelines, subject to the approval of the City Engineer. If necessary, additional pedestrian and sidewalk easements shall be provided on-site to construct a path of travel meeting ADA guidelines					
129	1/23/2019			EN36	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
Notes:					
ON-SITE:					
Development of the site is subject to the requirements of the National Pollution Discharge Elimination System (NPDES) Permit for the City of Rialto, issued by the Santa Ana Regional Water Quality Control Board, Board Order No. R8-2010-0036. Pursuant to the NPDES Permit, the developer shall ensure development of the site incorporates post-construction Best Management Practices (BMPs) in accordance with the Model Water Quality Management Plan (WQMP) approved for use for the Santa Ana River Watershed. The developer is advised that applicable Site Design BMPs will be required to be incorporated into the final site design, pursuant to a site specific WQMP submitted to the City Engineer for review and approval					






## Project Conditions City of Rialto

130	1/23/2019			EN37	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>ON-SITE:</b> The minimum pavement section for all on-site pavements shall be 2 inches asphalt concrete pavement over 4 inches crushed aggregate base with a minimum subgrade of 24 inches at 95% relative compaction, or equal. If an alternative pavement section is proposed, the proposed pavement section shall be designed by a California registered Geotechnical Engineer using "R" values from the project site and submitted to the City Engineer for approval					
131	1/23/2019			EN38	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>SANITARY SEWER:</b> The developer shall connect to the City of Rialto sewer system and apply for a sewer connection account with Rialto Water services					
132	1/23/2019			EN39	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>SANITARY SEWER:</b> Submit sewer improvement plans prepared by a California registered civil engineer to the Engineering Division for the extension of the existing sewer main line at Base Line Road. The plans shall be approved by the City Engineer prior to issuance of any building permits					
133	1/23/2019			EN40	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>SANITARY SEWER:</b> Prior to issuance of a certificate of occupancy or final City approvals, provide certification from Rialto Water Services to demonstrate that all water and/or wastewater service accounts have been documented					
134	1/23/2019			EN41	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>DOMESTIC WATER:</b> The developer is advised that domestic water service is provided by Fontana Water Services. The developer shall be responsible for coordinating with Fontana Water Services and complying with all requirements for establishing domestic water service to the property					
135	1/23/2019			EN-OTHER	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>WASTE MANAGEMENT:</b> In accordance with Section 8.08 – Refuse Collection of the City of Rialto Municipal Code, any and all refuse (including recycling) generation and disposal due to construction activities must adhere to City Council approved franchise agreements. Only City Council approve waste and refuse franchisee vendors can be used to dispose of generated waste.					






## Project Conditions City of Rialto

136	1/23/2019			EN42	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GRADING:</b> Submit a Precise Grading Plan prepared by a California registered civil engineer to the Engineering Division for review and approval. The Precise Grading Plan shall be approved by the City Engineer prior to issuance of a building permit					
137	1/23/2019			EN43	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GRADING:</b> Prior to commencing with any grading, the required erosion and dust control measures shall be in place. In addition, the following shall be included if not already identified: a. 6 foot high tan colored perimeter screened fencing b. Contractor information signage including contact information along the street frontage of Base Line Road. c. Post dust control signage with the following verbiage: "Project Name, WDID No., IF YOU SEE DUST COMING FROM THIS PROJECT CALL: NAME (XXX) XXX-XXX, If you do not receive a response, please call the AQMD at 1-800-CUT-SMOG/1-800-228-7664"					
138	1/23/2019			EN45	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GRADING:</b> Submit a Water Quality Management Plan identifying site specific Best Management Practices (BMPs) in accordance with the Model Water Quality Management Plan (WQMP) approved for use for the Santa Ana River Watershed. The site specific WQMP shall be submitted to the City Engineer for review and approval with the Precise Grading Plan. A WQMP Maintenance Agreement shall be required, obligating the property owner(s) to appropriate operation and maintenance obligations of on-site BMPs constructed pursuant to the approved WQMP. The WQMP and Maintenance Agreement shall be approved prior to issuance of a building permit, unless otherwise allowed by the City Engineer					
139	1/23/2019			EN46	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GRADING:</b> A Notice of Intent (NOI) to comply with the California General Construction Stormwater Permit (Water Quality Order 2009-0009-DWQ as modified September 2, 2009) is required via the California Regional Water Quality Control Board online SMARTS system. A copy of the executed letter issuing a Waste Discharge Identification (WDID) number shall be provided to the City Engineer prior to issuance of a grading or building permit. The developers contractor shall prepare and maintain a Storm Water Pollution Prevention Plan (SWPPP) as required by the General Construction Permit. All appropriate measures to prevent erosion and water pollution during construction shall be implemented as required by the SWPPP					
140	1/23/2019			EN47	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b> <b>GRADING:</b> A Geotechnical/Soils Report prepared by a California registered Geotechnical Engineer shall be required for and incorporated as an integral part of the grading plan for the proposed development. A copy of the Geotechnical/Soils Report shall be submitted to the Engineering Division with the first submittal of the Precise Grading Plan					





## Project Conditions City of Rialto

141	1/23/2019			EN48	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b>					
<b>GRADING:</b>					
All stormwater runoff passing through the site shall be accepted and conveyed across the property in a manner acceptable to the City Engineer. For all stormwater runoff falling on the site, on-site retention or other facilities approved by the City Engineer shall be required to contain the increased stormwater runoff generated by the development of the property. Provide a hydrology study to determine the volume of increased stormwater runoff due to development of the site, and to determine required stormwater runoff mitigation measures for the proposed development. Final retention basin sizing and other stormwater runoff mitigation measures shall be determined upon review and approval of the hydrology study by the City Engineer and may require redesign or changes to site configuration or layout consistent with the findings of the final hydrology study. The volume of increased stormwater runoff to retain on-site shall be determined by comparing the existing pre-developed condition and proposed developed condition, using the 100-year frequency storm					
142	1/23/2019			EN49	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b>					
<b>GRADING:</b>					
Direct release of on-site nuisance water or stormwater runoff shall not be permitted to the adjacent public streets. Provisions for the interception of nuisance water from entering adjacent public streets from the project site shall be provided through the use of a minor storm drain system that collects and conveys nuisance water to landscape or parkway areas, and in only a stormwater runoff condition, pass runoff directly to the streets through parkway or under sidewalk drains					
143	1/23/2019			EN50	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b>					
<b>GRADING:</b>					
Provide pad elevation certifications for all building pads in conformance with the approved Precise Grading Plan, to the Engineering Division prior to construction of any building foundation					
144	1/23/2019			EN51	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b>					
<b>GRADING:</b>					
Prior to issuance of a certificate of occupancy or final City approvals, demonstrate that all structural BMPs have been constructed and installed in conformance with approved plans and specifications, and as identified in the approved WQMP					
145	1/23/2019			EN52	PPD CONDITION
ENGINEERING DIV		MOISES PERALTA			
<b>Notes:</b>					
<b>GRADING:</b> Remove all graffiti within 24 hours pre-construction, during construction, and after a Certificate of Occupancy is issued					





## Project Conditions City of Rialto

147	1/23/2019			RW-OTHER	PPD CONDITION
RIALTO WATER SERVICE		CHIPPER GREENE			

### Notes:

Water: Rialto Water Services does not serve water in the area of the proposed development of a 99,999 square foot industrial warehouse building located on the north side of Baseline Avenue approximately 315 feet east of Palmetto Avenue within the Employment (EMP) zone of the Renaissance Specific Plan. The developer shall show proof of service being established with Fontana Water Company (FWC) and an authorization form signed to allow FWC to release water consumption information to Rialto Water Services (RWS) shall be completed prior to being issued a Certificate of Occupancy. This condition will not be required if the City of Rialto determines that no sewer connection is warranted at this time. All forms are available at the RWS/Veolia customer service office on 437 N. Riverside Avenue, Rialto, CA 92376. Sewer: Rialto Water Services serves sewer in the area of the proposed development, however the nearest existing sewer main is located ~ 680 linear feet east of the project on Baseline Avenue (intersection with Tamarind Avenue). If required to connect, the City of Rialto Public Works Department requires all sewer improvements to be constructed according to the City's Construction Standards. The developer shall show proof of service being established and a new service application shall be completed prior to being issued a Certificate of Occupancy. These documents can be obtained at our customer service office on 437 N. Riverside Avenue, Rialto, CA 92376. Industrial Pretreatment: The City of Rialto's Industrial Pretreatment Coordinator requires the applicant to submit a Non-Residential Sewer Service Application (IMP-01-A1). The applicant shall identify all process wastestreams (if any) and business operations that may have a potential to adversely impact the City's sewer conveyance system, wastewater treatment facilities, or its workers. The Industrial Pretreatment Coordinator will evaluate the submitted application and make a determination of classification. An application processing fee may apply. This application can be obtained at our customer service office on 437 N. Riverside Avenue, Rialto, CA 92376.



**DEVELOPMENT IMPACT FEE CALCULATIONS - PRELIMINARY (SUBJECT TO CHANGE)**  
**Industrial/Warehouse Fees Sheet**

<b>Date Prepared</b> 1/17/2019	<b>Building Permit #</b>	<b>PPD#</b> 2018-0021	<b>Applicant Name</b> CDRE Holdings	<b>Fiscal Year Fees</b> 2018-19
<b>Site Address:</b> N. on Baseline & E. of Palmetto	<b>Improved Area</b>	<b>Lot Size</b> 5.01 ac GROSS	<b>Building</b> <b>Sq. Footage</b> 99,999 bsf	<b>Parcel</b> <b>Frontage Linear Feet</b> 340
<b>APN:</b> 0240-181-32 & 33			Warehouse Use 96,163 bsf	
<b>Tract No:</b>			Storage Use - bsf	
			Office Use 3,836 bsf	

**FY 2018-19 Fee Estimate\***

City of Rialto Impact Fees	Agency	Unit	Fee/Unit	Fee Assessed	Fee Credit	Fees to be paid
Fire Facilities	City of Rialto	99.999 tsf	\$ 83.64	\$ 8,363.92	\$ -	\$ 8,363.92
Fire Service Development Fees (4", 6", 8", 10")	Fontana Water	1 in	\$ 4,048.30	\$ -	\$ -	\$ -
General Facilities	City of Rialto	99.999 tsf	\$ 69.80	\$ 6,979.93	\$ -	\$ 6,979.93
Law Enforcement	City of Rialto	99.999 tsf	\$ 51.11	\$ 5,110.95	\$ -	\$ 5,110.95
Open Space	City of Rialto	99.999 tsf	\$ 120.00	\$ 11,999.88	\$ -	\$ 11,999.88
Storm Drain	City of Rialto	5.010 ac	\$ 34,794.63	\$ 174,321.10	\$ -	\$ -
Storm Drain	City of Rialto	99.999 tsf	\$ 1,997.88	\$ 199,786.00	\$ -	\$ 199,786.00
Street Medians	City of Rialto	99.999 tsf	\$ 20.00	\$ 1,999.98	\$ -	\$ 1,999.98
Transportation Facilities Fee	City of Rialto	99.999 sf	\$ 2.80	\$ 279,997.20	\$ -	\$ 279,997.20
Water Facilities	Fontana Water	1 in	\$ -	\$ -	\$ -	\$ -
Wastewater Collection	City of Rialto	340 lff	\$ 8.34	\$ 2,835.60	\$ -	\$ 2,835.60
Wastewater Treatment - Warehouse Use	City of Rialto	96.163 tsf	\$ 191.83	\$ 18,446.95	\$ -	\$ 18,446.95
Wastewater Treatment - Office Use	City of Rialto	3.836 tsf	\$ 1,374.55	\$ 5,272.77	\$ -	\$ 5,272.77
<b>Total Impact Fees</b>			\$ 5.41		\$ -	\$ 540,793.18
<b>Fair Share Fees:</b>						
<u>Renaissance Specific Plan</u>						
RSP SR/EIR Fee*		5.01 ac	\$ 3,668.04	\$ 18,376.88	\$ -	\$ 18,376.88
RSP Traffic Mitigation Fair Share Fee		99.999 tsf	\$ 157.25	\$ 15,724.84	\$ -	\$ 15,724.84
<b>Total RSP Fair Share Fees</b>					\$ -	\$ 34,101.72
<u>Other Fair Share Fees</u>						
Fair Share Fee				\$ -	\$ -	\$ 31,200.00
				\$ -	\$ -	\$ -
				\$ -	\$ -	\$ -
				\$ -	\$ -	\$ -
				\$ -	\$ -	\$ -
<b>Total Other Fair Share Fees</b>				\$ -	\$ -	\$ 31,200.00

<b>Totals DIF Fees / Credits / Net Fees Due</b>	\$ -	\$ -	\$ 606,094.90
---	------	------	---------------



# City of Rialto

## Development Review Committee (DRC)

---

### DEPARTMENT & DIVISION CONTACTS

#### PLANNING DIVISION

**Gina Gibson-Williams**, Planning Manager  
Office: (909) 820-2535  
Direct: (909) 421-7240  
Email: [ggibson@rialtoca.gov](mailto:ggibson@rialtoca.gov)

**Daniel Casey**, Senior Planner  
Office: (909) 820-2535  
Direct: (909) 820-2525 x-2075  
Email: [dcasey@rialtoca.gov](mailto:dcasey@rialtoca.gov)

**Daniel Rosas**, Assistant Planner  
Office: (909) 820-2535  
Direct: (909) 820-8047  
Email: [drosas@rialtoca.gov](mailto:drosas@rialtoca.gov)

**Edgar Gonzalez**, Assistant Planner  
Office: (909) 820-2535  
Direct: (909) 820-2525 x-2211  
Email: [egonzalez@rialtoca.gov](mailto:egonzalez@rialtoca.gov)

#### BUSINESS LICENSING DIVISION

**Gina Gibson-Williams**, Planning Manager  
Office: (909) 820-2535  
Direct: (909) 421-7240  
Email: [ggibson@rialtoca.gov](mailto:ggibson@rialtoca.gov)

#### ECONOMIC DEVELOPMENT DIVISION

**John Dutrey**, Project Manager  
Direct: (909) 820-8014  
Email: [jdutrey@rialtoca.gov](mailto:jdutrey@rialtoca.gov)

#### RIALTO WATER SERVICES

**Chipper Greene**, Industrial Pretreatment Coordinator  
Direct: (951) 833-3470  
Email: [chipper.greene@veolia.com](mailto:chipper.greene@veolia.com)

#### BUILDING DIVISION

**James Caro**, Building & Code Enforcement Manager  
Office: (909) 820-2505  
Direct: (909) 421-4962  
Email: [jcaro@rialtoca.gov](mailto:jcaro@rialtoca.gov)

**John Walton**, Lead Building Inspector  
Office: (909) 820-2505  
Direct: (909) 820-8038  
Email: [jwalton@rialtoca.gov](mailto:jwalton@rialtoca.gov)

#### POLICE DEPARTMENT

**Sergeant Joshua Lindsay**  
Direct: (909) 820-2646  
Email: [jlindsay@rialtopd.com](mailto:jlindsay@rialtopd.com)

#### PUBLIC WORKS DEPARTMENT

**Moises Peralta**, Assistant Engineer  
Direct: (909) 421-7243  
Email: [mperalta@rialtoca.gov](mailto:mperalta@rialtoca.gov)

#### FIRE DEPARTMENT

**Kerrilyn Walton**, Assistant Fire Marshal  
Direct: (909) 820-2691  
Email: [kw Walton@confire.org](mailto:kw Walton@confire.org)

#### ADMINISTRATION DEPARTMENT

**Mayor Deborah Robertson**  
Office: (909) 421-4991  
Email: [aperry@rialtoca.gov](mailto:aperry@rialtoca.gov)

**Councilmember Andy Carrizales**  
Office: (909) 421-4991  
Email: [aperry@rialtoca.gov](mailto:aperry@rialtoca.gov)

---

#### COMMITTEE SECRETARY

**Adrianna Martinez**, Administrative Assistant  
Direct: (909) 421-7211  
Email: [ammartinez@rialtoca.gov](mailto:ammartinez@rialtoca.gov)